

**Marion County Environmental Dept.**  
**230 E. Main Marion, KS. 67063 620-382-2945**

**MINIMUM SEPARATION DISTANCES FOR WATER WELL:**

| AREA                              | MINIMUM DISTANCE |
|-----------------------------------|------------------|
| House                             | 25'              |
| Property Line                     | 25'              |
| Septic Tank/Absorption Field      | 100'             |
| Waste Stabilization Pond (Lagoon) | 100'             |
| Sewer Lines                       | 50'              |
| Barnyards, Stables, Animal Pens   | 100'             |
| Streams, Lakes, Ponds             | 50'              |
| Pit Privy                         | 100'             |

**MINIMUM SEPARATION DISTANCES FOR SEPTIC TANK-LATERAL FIELD SYSTEM:**

|                                 |                      |
|---------------------------------|----------------------|
| Private Water Well              | 100'                 |
| Property Line                   | 50'                  |
| House It Serves/Other Buildings | 10' (septic tank)    |
| House It Serves/Other Buildings | 25' (lateral fields) |
| Streams, Lakes, Ponds           | 100'                 |
| Existing Public Sewer System    | 400'                 |
| Public Water Well               | 100'                 |
| Public Water Transmission Lines | 25'                  |

**MINIMUM SEPARATION DISTANCES FOR WASTE STABILIZATION POND (LAGOON):**

|                                                                   |      |
|-------------------------------------------------------------------|------|
| Private Water Well                                                | 100' |
| Property Line, including right of way                             | 100' |
| Property Line with Written Permission of Adjacent Property Owners | 50'  |
| House It Serves                                                   | 100' |
| Other Residential Structures                                      | 250' |
| Streams, Lakes, Ponds                                             | 100' |
| Existing Public Sewer System                                      | 400' |
| Public Water Well                                                 | 100' |
| Public Water Transmission Lines                                   | 25'  |