

PERMITTING NOTES

- SITE TO BE GRADED AS SUCH TO HAVE POSITIVE DRAINAGE SOUTH TO THE DRAINAGE DITCH. A STORM WATER POLLUTION PREVENTION PLAN (SWPPP) PERMIT WILL BE OBTAINED FROM KDHE BEFORE CONSTRUCTION ACTIVITIES START.
 UPON APPROVAL OF CONDITIONAL USE PERMIT (CUP) A LOT SPIT WILL COMPLETED ON THE PARCEL.
 THE SUBSTATION WILL BE UNMANNED EXCEPT DURING CONSTRUCTION. REGULAR CHECKS AND MAINTENAANCE ON THE EQUIPMENT WILL OCCUR APPROXIMATELY
- ONCE A MONTH. 4. YARD LIGHTS WILL BE INSTALLED AND ONLY USED DURING EMERGENCIES. IF SECURITY BECOMES AN ISSUE, MOTION SENSING SECURITY LIGHTS MAY BE INSTALLED TO TEMPORARILY ILLUMINATE THE SUBSTATION.
- A FIRE PRE PLAN HAS BEEN DEVELOPED AND WILL BE GIVEN TO THE LOCAL FIRE DEPARTMENT SO THEY CAN RESPOND QUICKLY AND APPROPRIATELY.
 INTERNAL REVIEW FOR WETLANDS AND FLOOD PLAINS HAVE BEEN COMPLETED. NEITHER ARE PRESENT ONSITE.
- 7. STATE AND FEDERAL REVIEWS TO ASSESS THE IMPACT ON FAUNA, FLORA AND NEARBY HISTORICAL SITES HAVE BEEN COMPLETED AND APPROVED: – KANSAS DEPARTMENT OF WILDLIFE, PARKS & TOURISM (KDWPT)
- KANSAS HISTORICAL SOCIETY (KSHS)
- UNITED STATES FISH AND WILDLIFE SERVICE (USFWS)

JADE SUBSTATION DEVELOPMENT PLAN	DWG. NO. SXXXXX_PM01				
	SHEET	NÛ.			REV.
		1	OF	2	0