

Evergy, Inc.
JADE SUBSTATION
FIRE PRE PLAN
9/25/19

24 HOUR EMERGENCY PHONE (785) 234-9829

Should a fire or explosion occur within the substation fence, to prevent unnecessary risk to personnel, it is preferred that the substation be de-energized prior to any action taken towards the fire. Unless there is a threat to human life or possible damage to personal property outside the fence, no action should be taken until requested by a company representative. In case of a transformer oil fire, a class B foam suppression agent as outlined in the "Extinguishing Media and Fire Fighting Procedures" section of the MSDS sheet for electrical insulating oil can be used on the fire. Under no circumstances should water or foam be used on any energized part of the substation.